

LOAD SURVEY METERING / PHONE LINE SPECIFICATION

- 1. PHONE LINES ARE REQUIRED FOR ELECTRIC SERVICES 1000 AMPS 277/480 OR 2000 AMPS 120/208 AND GREATER
- 2. PHONE LINE SHALL BE A DEDICATED LINE. SINGLE PAIR. ANALOG TYPE. ACTIVATED WHEN 2 CONSECUTIVE MONTHS OF 800 KW IS REACHED; PER LPC'S REQUIREMENTS.
- 3. PHONE LINES SHALL BE INSTALLED IN 1/2" CONDUIT INTO THE LOWER PORTION OF THE METER HOUSING AND IN ACCORDANCE WITH THE N.E.C.
- 4. PIGTAILS IN THE HOUSING SHALL BE 12" LONG: TERMINATED WITH A PHONE JACK.
- 5. THIS SPECIFICATION HAS BEEN APPROVED BY THE CITY OF LONGMONT'S ELECTRICAL INSPECTOR AND NO ADDITIONAL CITY INSPECTION OF THE PHONE LINE IS REQUIRED.
- 6. LPC METERING DIVISION WILL CONFIRM THE SPECIFICATION HAS BEEN FOLLOWED. IF NOT FOLLOWED: LPC, AT ITS DISCRETION, MAY DISCONNECT THE SERVICE.
- 7. LPC IS AVAILABLE TO OPEN ENERGIZED SERVICES THAT REQUIRE THE ADDITION OF A PHONE LINE. CALL 303-651-8458

